

WED	DEPUTY DIRECTOR - DESIGN	2 22 December 2023 DATE
OVED	CHIEF ENGINEER	01/11/2024 DATE
	$\mathcal{O}$	22-DEC-2023

8). GROUND ROD SPREAD SHALL BE TWICE THE LENGTH OF THE GROUND ROD.

- AS DIRECTED BY INSPECTOR.
- WELL SHALL BE PLACED WITHIN 10' OF SERVICE PEDESTAL (OR PER PLAN). 7). CONCRETE COLLAR SHALL CONTAIN 25 LBS OF CONCRETE AT EACH LEG JUST BELOW GRADE
- UNLESS SPECIFIED DIFFERENTLY ON THE PLANS OR BY LOCAL UTILITY COMPANY. ALL CONDUITS SHALL BE INSTALLED FROM ENCLOSURE TO TYPE 1 JUNCTION WELL. JUNCTION
- **BOLTS AND NYLON LOCK NUTS.** 6). ALL CONDUITS AND OTHER ASSOCIATED PIECES SHALL BE 2" RIGID GALVINIZED CONDUIT
- 5). MOUNT CIRCUIT BREAKER BOX TO ALUMINUM PANEL WITH (4)  $\frac{5}{16}$ " x  $\frac{3}{4}$ " STAINLESS STEEL
- 4). MOUNT METER SOCKET TO ALUMINUM PANEL WITH (4)  $\frac{5}{16}$ " x  $\frac{3}{4}$ " STAINLESS STEEL BOLTS AND NYLON LOCK NUTS.
- 3). ATTACH ALUMINUM PANEL TO SIGN POSTS WITH (6)  $\frac{5}{16}$ " x  $2\frac{1}{2}$ " LONG GRADE 5 BOLTS, FLAT WASHERS, AND NYLON LOCK NUTS, 3 ON EACH SIDE.
- 2). SEE DETAIL T-15, SHEET 1, FOR SIGN POST AND BREAKAWAY ASSEMBLY DETAILS.
- CABINET SHALL BE AS PER CONTRACT DRAWINGS/DETAILS.
- **1). INSTALLATION OF EQUIPMENT BETWEEN SERVICE PEDESTAL AND LIGHTING/CONTROLLER**