



## **NOTES:**

- 1). THRIE-BEAM GUARDRAIL NOT SHOWN. SEE STANDARD NO. B-10 FOR MORE INFORMATION ON THRIE-BEAM CONNECTION.
- 2). FOUNDATION NOT SHOWN. FOR ROADSIDE BARRIER APPLICATIONS BUTTRESS SHALL BE CONSTRUCTED ON A MINIMUM 2'-0" WIDE x 2'-0" DEEP FOOTING OVER 8" OF GABC.
- 3). CHAMFER ALL EXPOSED EDGES 3/4" x 3/4", UNLESS NOTED OTHERWISE. 4). SEE SHEET 2 FOR BUTTRESS REINFORCEMENT.



12/22/2023 DATE RECOMMENDED

THRIE-BEAM APPROACH GUARDRAIL TRANSITION (AGT) TO CONCRETE BUTTRESS SHT. OF STANDARD NO. B-11 (2024)

CHIEF ENGINEER

**REVIEWED** 

**APPROVED** 

22-DEC-2023

TL-3

22 December 2023

DATE 01/11/2024 DATE